


Overview



"**Project settings (#1)**" This button takes you to the project-specific settings, e.g. to store the connection data and test the connection.

"**Access type (#2)**" Choose between "Local" and "Remote" so that the online functions (debug page, QuadClient) use the correct connection. The S1/RA functions are only available with "Remote".

"**Connect/Disconnect (#2)**" If the access data is stored, the connection is established and disconnected here.

Description Abendroth, Ellerstadt
Typ Experte (Gira+Feller)
Version 4.12
ID Experte 20190117185615940
IP Internal 192.168.178.50:443
IP External localhost:8081

ETS Projekt Attach 0 Projects attached
Update lock
Project password [password field] ⓘ [lock icon]
Project note Vorsicht, EMA über KNX

OpenVPN Import

ISE RA / Gira S1 [gear icon] [trash icon] Speed Check
Remote Access ID GI-S1YYYYT3

TCP-Ports:

| Activated | Port Local | IP address | Port Device | Comment |
|-------------------------------------|------------|----------------|-------------|-----------------------|
| <input checked="" type="checkbox"/> | 8081 | 192.168.178.50 | 443 | HomeServer Standard |
| <input checked="" type="checkbox"/> | 8082 | 192.168.178.60 | 80 | TKS-IP-GW WebGUI |
| <input checked="" type="checkbox"/> | 8080 | 192.168.178.60 | 8080 | TKS-IP-GW Redirection |
| <input type="checkbox"/> | | | | |

